

Environmental Claim Validation

Certificate

418954-4710

Issue Date

14 Dec 2024

Expiration Date

14 Dec 2026



Ranee Valles
Director and General Manager

UL Verification Services Inc.
2211 Newmarket Parkway, ste 106
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

FILT AIR LTD

for the following product:

Sterionizer AHU Bar

The product has been evaluated and meets the requirements for:

Claim:

Zero Ozone Emissions – Measured Ozone Emissions from DMR-6000 during use phase does not exceed 0.005 ppm as tested by UL 867.

Method:

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

Facility:

Zikhron Yaaqov