

Environmental Claim Validation

Certificate

260727-4710

Issue Date

14 Dec 2020

Expiration Date

14 Dec 2026



Ranee Valles
Director and General Manager

UL Verification Services Inc.
2211 Newmarket Parkway, ste 106
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

FILT AIR LTD

for the following product:

Sterionizer D6 Duct Unit

The product has been evaluated and meets the requirements for:

Claim:

Zero Ozone Emissions – Measured Ozone Emissions from Sterionizer™ D6 Series during use phase does not exceed 0.005 ppm as tested by UL 867.

Method:

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

Facility:

Filt Air Ltd.

UL Solutions evaluated representative samples of the identified product, process or facility to the identified Standard or other requirements in accordance with the agreements and any applicable program service terms in place between UL Solutions and the Client (collectively "Agreement"). The Client is authorized to use the UL Mark for the identified Product, process or facility covered by this certificate, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement. This certificate is subject to modification, suspension and withdrawal by UL Solutions see SPOT.ul.com, to authenticate the certificate.